

# W7350A1000 CD Installation and Software Update

## INSTALLATION INSTRUCTIONS

**NOTE:** Honeywell recommends that before you install the WebStat in a customer site, you load the latest release of the software on to the WebStat platform.

Please use the enclosed CD-ROM, part number #50030935-001, to save the software file update v01.02.03 to your local PC hard drive or desktop. Alternatively, you can download the latest WebStat software update from <http://customer.honeywell.com/Business/Cultures/en-US/Products/Applications+and+Downloads/>.

The latest update, v01.02.03, provides performance enhancements as well as compatibility for Internet Explorer v7.0. The performance enhancements allow your controller to more effectively execute and update the firmware memory operations. It is strongly advised to load the v01.02.03 update to ensure that proper performance is achieved over the duration of the product installment period.

After the software file is loaded to the PC hard drive or desktop, the file can be uploaded into the WebStat controller using the following directions:

## INSTALLATION PROCESS

1. Download the update software to your local PCs from the CD-ROM or from the above <http://> link and save it to a known location on your hard drive.
2. Connect to the WebStat per the instructions you received with the product regarding configuring the network settings. See the Quick Start Guide 63-2657 for instructions.
3. Open your browser interface and navigate to the WebStat login screen. See the Quick Start Guide 63-2657 for instructions.
4. Once you have logged in, navigate to the SETUP screen and GENERAL TAB.
5. Make backup of your configuration by pressing the BACKUP CONFIGURATION button at the top of this screen and save the file to your local hard drive.
6. Then from the item labeled Software Update Package on the same screen, select the upgrade file v01.02.03 from your local hard drive on your PC using the Browse Button.
7. Press the Upload Button to install the software. The WebStat will automatically reboot during this process.
8. After 5 to 8 minutes, the WebStat should have rebooted and you can now access the system again.
9. Note that the current version of software for WebStat is shown in the upper left hand corner, as seen in Fig. 1.



The screenshot displays the Honeywell WebStat software interface. At the top, the 'WebStat™' logo is on the left, and the date 'Dec 14, 2007 12:16pm' along with 'Help' and 'Logout' links are on the right. A navigation bar contains tabs for 'Overview', 'Floor Plans', 'Schedules', 'Alarms', 'Trends', 'Users', 'Thermostats', and 'System'. Below this, a status bar shows 'Logged in as Honeywell Contractor' and 'Outside Temperature: 0 °F | Weather Underground'. A secondary navigation bar includes 'General', 'Email Setup', 'Network Setup', and 'Login Page Setup'. The main content area is titled 'System' and includes a 'Software Update Package' section with a 'Browse...' button and an 'Upload' button. Below this are buttons for 'Backup Configuration', 'Restore Configuration', and 'Reboot WebStat'. The 'Time and Date Settings' section features fields for 'Time' (12 : 16), 'Date' (12/14/2007), 'Time Server Address' (time-a.nist.gov), and 'Time Zone' (US/Eastern (-5/-4)). It also has checkboxes for 'Use Internet Time Server' and 'Webstat is Network Time Master', both with 'Sync Now' buttons. The 'Engineering units' section has radio buttons for 'US English' (selected) and 'Metric'. The 'Local Weather And Outdoor Air Temperature' section includes a dropdown for 'Select a thermostat to display outside temperature' (RTU\_5 Third floor), and text input fields for 'Enter external link URL' (http://www.weatherunderground.com/) and 'Enter external link title' (Weather Underground). A 'Save' button is located at the bottom right of the interface.

Fig. 1. WebStat software version.

**Automation and Control Solutions**

Honeywell International Inc.  
1985 Douglas Drive North  
Golden Valley, MN 55422  
customer.honeywell.com

Honeywell Limited-Honeywell Limitée  
35 Dynamic Drive  
Toronto, Ontario M1V 4Z9

